

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:49 pm

PWS ID: UTAH25008 **Name:** AMERICAN FORK CITY

Legal Contact: AMERICAN FORK CITY **Rating:** Approved
STEPHEN C PARKER **Rating Date:** 03/04/1980

Address: 51 E MAIN ST **Activity Status:** Active
AMERICAN FORK, UT 84003-2381

Phone Number: 801-763-3050

City Served (Area):

County: UTAH COUNTY

System Type: Community **Last Inv Update:** 07/18/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 10/29/2007 **Total Dsgn Cap:**
Population: 23,000 **Surveyor:** BRIAN NIELSON **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	PARKER, STEPHEN C		801-763-3050	801-756-5736	stevep@afcity.net

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered/Unm	0	7,300
			7,300 Total Svc Connections

Storage

Total Storage: 14,750,000 G³ **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	UPPER TANK #1	Ground	5,000,000 GAL	Concrete		A	NO
ST002	UPPER TANK #2	Ground	5,000,000 GAL	Concrete		A	NO
ST003	LOWER TANK	Ground	4,750,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	TIMP CAVE CAMP SPRING CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	TIMP CAVE CAMP SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	POWER HOUSE SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS003	J.C.PARK WELL	Inactive	WL	16	2600 GPM		Yes	GW	Seasonal		
WS004	1ST EAST WELL	Inactive	WL	12	650 GPM		Yes	GW	Other		

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS005	6TH EAST WELL	Inactive	WL	16	1200 GPM		Yes	GW	Other		
WS006	HOSPITAL WELL	Active	WL	16	2000 GPM		Yes	GW	Seasonal	1/1 to 12/31	
WS007	RACE TRACK WELL	Active	WL	20	3200 GPM		Yes	GW	Seasonal		
WS008	ALPINE COUNTRY CLUB WE	Active	WL	16	2800 GPM		Yes	GW	Seasonal		
WS009	BOLEY WELL	Active	WL	16	2925 GPM		Yes	GW	Seasonal		
WS010	GOLF COURSE WELL	Active	WL	14	3500 GPM		Yes	GW	Seasonal		

**Reports measured flow for wells, approved design capacity for all other sources.*